

CERTIFICATE OF PRODUCT CONFORMITY

Dubai Central Laboratory Department (DCLD) of Dubai Municipality
hereby attests that the product(s)

Aluminum Composite Panel (ACP)

(Details as per the attached Scope of Certification)

manufactured by:

EMERGE METAL INDUSTRY LLC

R288-290, AL GHAIL INDUSTRIAL AREA , RAS AL KHAIMA

have been assessed in accordance with DCLD Document Ref. No. DM-DCLD-RD-DP21-2001 (IC) "General Rules for DM third party product certification system through factory assessment" and the relevant Specific Rules, and were found in conformity with the standard specification:

DMS 036 : 2021

Accordingly, DCLD hereby authorizes the above manufacturer
to affix the DCL Product Conformity Mark on the above-mentioned product(s).

for / ENGR. AMIN AHMED AMIN
Director, Dubai Central Laboratory Department
Dubai Municipality

Certificate No: CL21020779
Valid Until: 26/07/2022



Current Issue Date: 27/07/2021
Original Issue Date: 27/07/2021



The attached Scope of Certification bearing the same Certificate Number forms an integral part of this Certificate.
This Certificate is an electronic document subject to the Terms and Conditions of the Product Certification System and shall not be reproduced except in full.

**DUBAI CENTRAL LABORATORY DEPARTMENT
DCL PRODUCT CONFORMITY CERTIFICATION SCHEME**

**SCOPE OF CERTIFICATION
FOR CERTIFICATE NO. CL21020779**

Certificate Issued To: EMERGE METAL INDUSTRY LLC
R288-290, AL GHAIL INDUSTRIAL AREA , RAS AL KHAIMA,UAE

Applicable Standard Specification: DMS 036 : 2021 “Standard Specification for Aluminum Composite Panel”

Applicable Specific Rules: DM-DCLD-RD-DP21-2214 (IC) - Specific Rules for Certification of Aluminum Composite Panel Through Factory Assessment.

S/N	PRODUCT DESCRIPTION	BRAND NAME	PRODUCT DETAILS
1	Aluminum Composite Panel	Emerge UK FR A2	Panel thickness : 4 mm (+/- 0.2 mm) Product Performance meet the (Table 3) DMS-036 requirements
2	Aluminum Composite Panel	Emerge UK FR Plus	Panel thickness : 4 mm (+/- 0.2 mm) Product Performance meet the (Table 3) DMS-036 requirements

NOTE 1: This document forms part of the Certificate of Product Conformity bearing the same Certificate Number.

NOTE 2: The above product shall bear the DCL Conformity Mark (applied on each product or on the packaging).

NOTE3: The license shall only be for the product “as panels” and shall not cover the “cladding” systems made from these panels.

Original Issue Date : 27/07/2021

Current Issue Date : 27/07/2021

Valid Until : 26/07/2022



ARIF HUSAIN AL MARZOOQI

Products Conformity Assessment Section Manager
Dubai Central Laboratory Department